

SVGW
Schweizerischer Verein des
Gas- und Wasserfaches
Grütlistrasse 44
CH-8027 Zürich

Zertifizierungsstelle Gas
Schweizerischer Verein des
Gas- und Wasserfaches
Eschenstrasse 10
CH-8603 Schwerzenbach



ZERTIFIKAT Nr. 03-073-6

Antragsteller: Georg Fischer RLS (Schweiz) AG, Ebnetstrasse 101, CH-8201 Schaffhausen
Hersteller: Rasmussen GmbH, Edisonstrasse 4, D-63477 Maintal

Gestützt auf das Prüf- und Zertifizierungsreglement der Technischen Prüfstelle Gas des SVGW sowie auf den Bericht Nr. 03-072...74-6 (Beg.) zertifiziert der SVGW die folgenden Serienprodukte:

Produkt: Kraftschlüssige, lösbare Glattrrohrverbinder für Rohre aus PEHD
Stamm-Bezeichnung: +GF+ NORMA PLAST-GRIP
Modelle/Typen:
PG1-W2...NBR für Rohranschluss-Ø 40 bis 110 mm
PG1-W4...NBR für Rohranschluss-Ø 40 bis 110 mm (vollständig rostfrei)
PG1-W5...NBR für Rohranschluss-Ø 40 bis 110 mm (vollständig rostfrei)

Prüfgrundlage: DVGW VP 600 (07.2001)

Zertifizierungsgrundlage: Prüfberichte der Baumusterprüfungen und Kontrollberichte von der Prüfstelle am Süddeutschen Kunststoffzentrum (SKZ) in Würzburg

Gültigkeit: bis zum 28.02.2014 (Verlängerung)

Zertifiziert für:

- einen Betriebsdruck von max. 5 bar
- Umgebungstemperaturen von -20°C bis + 70°C
- Erdgas, Propan/Luft und Flüssiggase im gasförmigen Zustand

Der Auftraggeber ist somit berechtigt, diese Produkte als SVGW-zertifiziert anzubieten und das SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Gas unter Kapitel 6.3)



akkreditiert nach
SN EN 45011
SCESp 025

Schweizerischer Verein des Gas- und Wasserfaches

Leiter Zertifizierungsstelle

Zertifizierungsstelle


Javier Fernandez


Klaus Frick

Zürich, 16.06.2009

SGWA
Swiss Gas and Water
Industry Association
Grütlistrasse 44
CH-8027 Zurich

Certification Body Gas
Swiss Gas and Water
Industry Association
Eschenstrasse 10
CH-8603 Schwerzenbach



CERTIFICATE No. 03-073-6

Applicant: Georg Fischer RLS (Schweiz) AG, Ebnetstrasse 101, CH-8201 Schaffhausen
Manufacturer: Rasmussen GmbH, Edisonstrasse 4, D-63477 Maintal

Supported by the testing and certification regulation gas from the SGWA technical body gas, the SGWA certify on the base of the certification report no. **03-072..74-6 (Beg.)** the following products:

Product: Unlockable friction-type coupling for polyethylene plastic pipes (PE 100)
Serial name: +GF+ NORMA PLAST-GRIP
Types: PG1-W2...-NBR for tube dimensions \varnothing 40 mm up to 110 mm
PG1-W4...-NBR for tube dimensions \varnothing 40 mm up to 110 mm
PG1-W5...-NBR for tube dimensions \varnothing 40 mm up to 110 mm

Specified requirements: DVGW VP 600 (Ed.11.1996)

Base of certification: Test report (type test) and reports of check tests from the testing laboratory SKZ in Würzburg (Germany)

Validity: 28.02.2014 (renewal)

Certification: - for a pressure of service of max. 5 bar
- for an ambient temperature from -20°C up to +70°C
- for natural gas, air propane, liquefied petroleum gas (gaseous)

The holder of this certificate is authorized to offer these products as SGWA-certified and to use the SGWA label of conformity (publication in the gas certification listing, chapter 6.3)



accredited according to
SN EN 45011
SCESp 025

Swiss Gas and Water Industry Association

Head Certification Body


Javier Fernandez

Referee Certification Body


Klaus Frick

Zurich, 16.06.2009